

**CLASSIFICATION OF REACTION TO FIRE  
FOR ELECTRIC CABLES  
IN ACCORDANCE WITH EN 13501-6**

**of**

**JIAXING HAITANG ELECTRONICS CO., LTD**

**Cable identification:**

**U/UTP Cat. 6A PVC Copper cable**

Prepared by Jens Rytter Petersen

Project No. 1164611

2016.10.12



<b>Table of contents</b>	<b>Page</b>
<b>1 Identification</b>	<b>3</b>
<b>2 Details of classified products</b>	<b>4</b>
<b>2.1 General</b>	<b>4</b>
<b>2.2 Product description</b>	<b>4</b>
<b>3 Reports and results in support of this classifications</b>	<b>5</b>
<b>3.1 Reports</b>	<b>5</b>
<b>3.2 Results</b>	<b>6</b>
<b>4 Classification and field of application</b>	<b>7</b>
<b>4.1 Reference of classifications</b>	<b>7</b>
<b>4.2 Classification</b>	<b>7</b>
<b>4.3 Field of application</b>	<b>8</b>
<b>5 Limitations</b>	<b>9</b>

## 1 Identification

Sponsor: JIAXING HAITANG ELECTRONICS CO., LTD  
1<sup>st</sup> Jinggong Rd,  
Yandong Village,  
Wuyuan Town,  
Haiyan , Zhejiang  
China

Quentin Tan  
quentin.tan@scscable.com

Prepared by: 3P Third Party Testing      Email: 3Ptest@3Ptest.dk  
Agern Allé 3      Phone: + 45 45572200  
DK-2970 Hoersholm      Fax: + 45 45765708  
Denmark      Homepage: <http://www.3Ptest.dk>

CPR Notified Body No.: **NB 2652**

DANAK Reg. No.: **0473**

Product name: U/UTP Cat. 6A PVC Copper cable

Product Marking HT CAT6A-024-0810-0500 U/UTP CATEGORY 6A CLASS  
EA UNSHIELDED PVC CABLE VERIFIED to CAT6A  
ISO/IEC-11801 315M

Classifications report No.: 1164611

Issue number: 1

Date of issue: 2016.10.12

This classification report consists of nine pages and may only be used or reproduced in its entirety.

## 2 Details of classified products

### 2.1 General

The product, U/UTP Cat. 6A PVC Copper cable, is defined as a copper communication cable according to EN 50575.

### 2.2 Product description

The product U/UTP Cat. 6A PVC Copper cable, is described below or is described in the reports provided in support of classifications listed in 3.1.

<b>Product descriptions</b>
U/UTP Cat. 6A PVC Copper cable.

### 3 Reports and results in support of this classifications

#### 3.1 Reports

<b>Name of Laboratory</b>	<b>Name of sponsor</b>	<b>Report ref. No.</b>	<b>Test method and date/field of applications rules and date</b>
3P	JIAXING HAI TANG ELECTRONICS CO., LTD	Report no. 1164611A	EN 60332-1-2

### 3.2 Results

Test method and test number	Parameter	No. Tests	Results	
			Continuous parameter – mean	Compliance with parameters
EN 60332-1-2 Report no. 1164611A	$H \leq 425$ mm	1	100 mm	Compliant

## 4 Classification and field of application

### 4.1 Reference of classifications

This classification has been carried out in accordance with EN 13501-6

### 4.2 Classification

The product, U/UTP Cat. 6A PVC Copper cable, in its relations to reaction to fire behaviour is classified:

A<sub>ca</sub> to F<sub>ca</sub> (as applicable)

The additional classification in relation to smoke production is:

s1, s1a, s1b, s2, s3, (as applicable)

The additional classification in relation to flaming droplets / particles is:

d0, d1, d2, (as applicable)

The additional classification in relation to acidity is:

a1, a2, a3, (as applicable)

The format of the reactions to fire classification for electric cables is:

<b>Fire behaviour</b>		<b>Smoke production</b>		<b>Flaming droplets</b>		<b>Acidity</b>
E <sub>ca</sub>	,		,		,	

### 4.3 Field of application

This classification is valid for the following product parameters as determined in the extended applications process CLC/FprTS 50576.

<b>Product family:</b> U/UTP Cat. 6A PVC Copper cable	
<b>Cable Identification:</b>	<b>Product parameter variations</b>
6AUU-001-101-PC 6AUU-001-201-PC 6AUU-001-301-PC 6AUU-001-135-PC 6AUU-001-235-PC 6AUU-001-335-PC 6AUU-001-110-PC 6AUU-001-210-PC 6AUU-001-310-PC	<b>Different colour,          length and          packing form</b>



## 5 Limitations

This classification document does not represent type approval or certifications of the product.

Include the following statement to the report when the product is being CE marked under the attestations of conformity system 3.

“The classification assigned to the product in this report is appropriate to a declaration of conformity by the manufacture within the context of system 3 attestation of conformity and CE marking under the Construction Product Regulation.

The test laboratory has therefore, played no part in sampling the product for the test, although it holds appropriate references, supplied by the manufacturer, to provide for traceability of the samples tested.”

Hoersholm, 12<sup>th</sup> October 2016



---

Jens Rytter Petersen  
Undertaking classification

Hoersholm, 12<sup>th</sup> October 2016



---

Morten Dam  
Authorizing this report