

Certificate of constancy
of performances



Notified body 2658

2658-CPR-5015_FAM095

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Data Transmission Cable F/FTP Cat 6/6A/7/7A/8 LSZH - Cables for general application in construction works subject to reaction to fire requirements (see family range in appendix)

Placed on the market by

Jiaxing Haitang Electronics Co., Ltd.

1st Jinggong Rd, Yandong Village, Wuyuan Town
314304 Zhejiang - China

And produced in the manufacturing plant

Jiaxing Haitang Electronics Co., Ltd.

1st Jinggong Rd, Yandong Village, Wuyuan Town
314304 Zhejiang - China

This certificate attests that all provisions concerning the assessment and verification of constancy of performances detailed in annex ZZ of the standard

EN 50575:2014 + A1:2016

Under system 1+ for the performances set out here below are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

Level of class of performance: B2_{ca}-s1a,d0,a1

This certificate was first issued on 2019/06/20 and will remain valid as long as the test methods and/or factory production control requirements included harmonized standard, used to assess the performance of the declared essential characteristic, do not change, and the construction product, and the manufacturing conditions in the plant are not modified significantly, unless suspended or withdrawn by the product certification body.

Brussels, 2019/06/20

C. LANA

Certification Manager



SGS



SGS Belgium NV – Division SGS CEBEC
Riverside Business Park
Bld. Internationalelaan, 55 Build. D
BE-1070 Brussels
Tel. +32 2 556 00 20
Fax +32 2 556 00 36

FAM095		
Cable type	Product code	Family Name
F/FTP Cat 6/6A/7/7A/8 LSZH 23 AWG	HT-FFTP-XXX	F/FTP Cat 6/6A/7/7A/8 LSZH
XXX: colour & packaging length		

The test results are laid down in certification file ref.630309/06

This certificate is based on test reports ref. L1CPRT775 and 630309.06